Certificate of Analysis

M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Laboratory No.: 2633498
Reported: 08/28/26
Lab Contact: Paulina Laudan Webb

Lab ID: 2633498-02 **Collected By:** Client **Sampled:** 08/21/26 13:07 **Received:** 08/26/26 14:35
Sample Desc: 850 N. 5th St. 1st floor **Sample Type:** Grab
Notes:

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst	EPA MCL Min/Max		Pass/ Fail
Total Metals										
Lead	0.003	mg/L	0.001	EPA 200.8 Rev 5.4	08/27/26		MPB	N/A	0.015	*

107 Angelica Street ❍ Reading, PA 19611 ❍ www.mjreider.com ❍ (610) 374-5129 ❍ fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

Certificate of Analysis

M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Laboratory No.: 2633498
Reported: 08/28/26
Lab Contact: Paulina Laudan Webb

Lab ID: 2633498-03 **Collected By:** Client **Sampled:** 08/21/26 13:20 **Received:** 08/26/26 14:35
Sample Desc: 136 S. 4th St. 2nd floor **Sample Type:** Grab
Notes:

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst	EPA MCL Min/Max		Pass/ Fail
Total Metals										
Lead	0.002	mg/L	0.001	EPA 200.8 Rev 5.4	08/27/26		MPB	N/A	0.015	*

107 Angelica Street ❍ Reading, PA 19611 ❍ www.mjreider.com ❍ (610) 374-5129 ❍ fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

Certificate of Analysis

M.J. Reider Associates, Inc.
ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Laboratory No.: 2633498
Reported: 08/28/26
Lab Contact: Paulina Laudan Webb

Lab ID: 2633498-04 **Collected By:** Client **Sampled:** 08/21/26 13:26 **Received:** 08/26/26 14:35
Sample Desc: 136 S. 4th St. 1st floor **Sample Type:** Grab
Notes:

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst	EPA MCL Min/Max		Pass/ Fail
Total Metals										
Lead	<0.001	mg/L	0.001	EPA 200.8 Rev 5.4	08/27/26		MPB	N/A	0.015	*

107 Angelica Street ❍ Reading, PA 19611 ❍ www.mjreider.com ❍ (610) 374-5129 ❍ fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

Certificate of Analysis

M.J. Reider Associates, Inc.
ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Laboratory No.: 2633498
Reported: 08/28/26
Lab Contact: Paulina Laudan Webb

Lab ID: 2633498-05 **Collected By:** Client **Sampled:** 08/21/26 13:30 **Received:** 08/26/26 14:35
Sample Desc: 136 S. 4th St. 1st floor (2) **Sample Type:** Grab
Notes:

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst	EPA MCL Min/Max		Pass/ Fail
Total Metals										
Lead	0.001	mg/L	0.001	EPA 200.8 Rev 5.4	08/27/26		MPB	N/A	0.015	*

107 Angelica Street ❍ Reading, PA 19611 ❍ www.mjreider.com ❍ (610) 374-5129 ❍ fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

Certificate of Analysis

M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Laboratory No.: 2633498
Reported: 08/28/26
Lab Contact: Paulina Laudan Webb

Lab ID: 2633498-07 **Collected By:** Client **Sampled:** 08/21/26 13:44 **Received:** 08/26/26 14:35
Sample Desc: 131 W Hamilton St. **Sample Type:** Grab
Notes:

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst	EPA MCL Min/Max		Pass/ Fail
Total Metals										
Lead	<0.001	mg/L	0.001	EPA 200.8 Rev 5.4	08/27/26		MPB	N/A	0.015	*

Notes and Definitions

* Maximum contaminant limits of 0.005 mg/l for Lead and 1.0 mg/l for Copper apply to bottled/purchased water. Averaged maximum contaminant limits of 0.015 mg/l for Lead and 1.3 mg/l for Copper apply to public water supplies.

Pass Result less than or equal to EPA maximum contaminant level.

Fail Result greater than EPA maximum contaminant level.

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

Certificate of Analysis

M.J. Reider Associates, Inc.
ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Laboratory No.: 2642339
Reported: 10/02/26
Lab Contact: Paulina Laudan Webb

Attention: Greg Ness
Reported To: ABE Lab
7596B Beth-Bath Pike
Bath, PA 18014

Project: Roberto Clemente Charter School

Lab ID: 2642339-01 **Collected By:** Client **Sampled:** 09/29/26 11:08 **Received:** 10/01/26 13:00
Sample Desc: 830 N 5th Street 2nd Floor **Sample Type:** Grab
Notes:

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst	EPA MCL Min/Max		Pass/ Fail
Total Metals										
Lead	0.001	mg/L	0.001	EPA 200.8 Rev 5.4	10/01/26		MPB	N/A	0.015	*

107 Angelica Street ❍ Reading, PA 19611 ❍ www.mjreider.com ❍ (610) 374-5129 ❍ fax (610) 374-7234

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

Certificate of Analysis

M.J. Reider Associates, Inc.
ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Laboratory No.: 2642339
Reported: 10/02/26
Lab Contact: Paulina Laudan Webb

Lab ID: 2642339-02 **Collected By:** Client **Sampled:** 09/28/26 11:30 **Received:** 10/01/26 13:00
Sample Desc: 136 S 4th Street Basement **Sample Type:** Grab
Notes:

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst	EPA MCL Min/Max		Pass/ Fail
Total Metals										
Lead	<0.001	mg/L	0.001	EPA 200.8 Rev 5.4	10/01/26		MPB	N/A	0.015	*

Notes and Definitions

* Maximum contaminant limits of 0.005 mg/l for Lead and 1.0 mg/l for Copper apply to bottled/purchased water. Averaged maximum contaminant limits of 0.015 mg/l for Lead and 1.3 mg/l for Copper apply to public water supplies.

Pass Result less than or equal to EPA maximum contaminant level.

Fail Result greater than EPA maximum contaminant level.

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

M.J. Reider Associates, Inc.
107 Angelica St, Reading PA, 19611
610-374-5129 www.mjreider.com

WORK ORDER
Chain of Custody

2633498

Client Code: 1485
Project Manager: Paulina Laudan Webb
Report To: ABE Lab - Greg Ness - 7596B Beth-Bath Pike, Bath, PA 18014
Invoice To: ABE Lab - Greg Ness - 7596B Beth-Bath Pike, Bath, PA 18014

Client: ABE Lab
Project: Roberto Clemente Charter School

Collected By: (Full Name) James Devereaux

Comments: ① Per customer ES 8/21/26

2633498-01	850 N. 5th St. 2nd floor	**Matrix:** Drinking Water	**Type:** Grab	Date/Time:	8/21/26 1:00 PM
Pb EPA 200.8		A - Pl 250mL leak-proof (Nalgene) HNO3			
2633498-02	850 N. 5th St. 1st floor	**Matrix:** Drinking Water	**Type:** Grab	Date/Time:	8/21/26 1:07 PM
Pb EPA 200.8		A - Pl 250mL leak-proof (Nalgene) HNO3			
2633498-03	136 S 4th St. 2nd floor ①	**Matrix:** Drinking Water	**Type:** Grab	Date/Time:	8/21/26 1:26 PM
Pb EPA 200.8		A - Pl 250mL leak-proof (Nalgene) HNO3			
2633498-04	136 S 4th St. 1st floor ①	**Matrix:** Drinking Water	**Type:** Grab	Date/Time:	8/21/26 1:26 PM
Pb EPA 200.8		A - Pl 250mL leak-proof (Nalgene) HNO3			
2633498-05	136 S 4th St. 1st Floor (2) ①	**Matrix:** Drinking Water	**Type:** Grab	Date/Time:	8/21/26 1:38 PM
Pb EPA 200.8		A - Pl 250mL leak-proof (Nalgene) HNO3			
2633498-06	136 S 4th St. Basement ①	**Matrix:** Drinking Water	**Type:** Grab	Date/Time:	8/21/26 1:32 PM
Pb EPA 200.8		A - Pl 250mL leak-proof (Nalgene) HNO3			
2633498-07	131 W Hamilton St. ①	**Matrix:** Drinking Water	**Type:** Grab	Date/Time:	8/21/26 1:44PM
Pb EPA 200.8		A - Pl 250mL leak-proof (Nalgene) HNO3			

James Devereaux	8/21/26	Kathryn Silvagni	8/21/26 1406
Relinquished By	Date/Time	Received By	Date/Time
Kathryn Silvagni	AUG 26 2026 1211		AUG 26 2026 1211
Relinquished By	Date/Time	Received By	Date/Time
			AUG 26 2026 1435
Relinquished By	Date/Time	Received at Laboratory By	Date/Time

Sample Kit Prepared By: JSV	Date: JUL 20 2026
Temp at Receipt: 1.9 °C	Therm ID: T0013
Received on Ice: Yes ☑ No ☐	
Samples Arrived Intact: Yes ☑ No ☐	
Checked By: AEJ	Entered By: RLH

The Client, by signing (or having the client's agent sign), agrees to MJRA's Terms and Conditions and to pay for the above requested services including any additional associated fees incurred.

Report Template: wko WorkOrder COC ls

Certificate of Analysis

M.J. Reider Associates, Inc.

ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Laboratory No.: 2633498
Reported: 08/28/26
Lab Contact: Paulina Laudan Webb

MJRA Terms & Conditions

All samples submitted must be accompanied by signed documentation representing a Chain of Custody (COC). The COC Record acts as a contract between the client and MJRA. Signing the COC form gives approval for MJRA to perform the requested analyses and is an agreement to pay for the cost of such analyses, including any RUSH surcharges that may need to be applied. COC Records must be completed in black or blue indelible ink (must not run when wet). COC documentation begins at the time of sample collection. Client is required to document all sample details prior to releasing samples to MJRA. If applicable, samples must be placed on ice immediately after sampling and shipped or delivered to the laboratory in a manner that will maintain the sample temperature above freezing and below 6C (or 10C for microbiological analyses) (loose ice is preferred).

Sample Submission, Sample Acceptance & Sampling Containers

Included on the COC must be the sample description, date and time of collection (including start and stop for composites), container size and type, preservative information, sample matrix, indication of whether the sample is a grab or composite, who the sample was collected by, number of containers & a list of the tests to be performed. Any SDWA compliance testing samples must include all required PWSID info and client agrees to MJRA SDWA Terms & Conditions. Poor sample collection technique, inappropriate sampling containers and/or improper sample preservation may lead to sample rejection. Suitable sample containers, labels, and preservatives (as applicable), along with blank COCs can be provided upon request. Any Field Blank or Trip Blank that must be analyzed will be processed and charged as an additional sample.

Turnaround Times (TAT)

TAT for most test results range from 10 to 15 business days depending on the specific analyses and time of year submitted. Faster turnaround times (*RUSH TAT) may be available depending on the current workload in a particular department and the nature of the analyses requested. We encourage you to verify requests for expedited sample results with one of our Project Managers prior to sample submittal. Without confirmation from a Project Manager, your results may not be completed by your deadline. RUSH TAT cannot be guaranteed. *RUSH TAT Surcharges are applied for expedited turnaround times.

Analytical Results, Sample Collection Integrity, Subcontracting & Record Retention

Analytical values are for the sample as submitted and relate only to the item tested. The value indicates a snapshot of the constituent content of the sample at the time of sample collection. Analytical results can be impacted by poor sample collection technique and/or improper preservation. All sample collection completed by MJRA was performed in accordance with applicable regulatory protocols or as specified in customer specific sampling plans. Constituent content will vary over time based on the matrix of the sample and the physical and chemical changes to its environment. If samples with high concentrations and/or samples of high strength matrices that result in the need for extensive instrument cleanup, or cause damage to internal parts, a charge of $500 will be incurred. All sample results and laboratory reports are strictly confidential. Results will not be available to anyone except the primary client or authorized party representing the client unless MJRA receives additional permissions from the client. When necessary, MJRA will subcontract certain analyses to a third party accredited laboratory. If client prohibits subcontracting, it must be provided in writing and include instruction on how to proceed with client samples that require third party analyses. MJRA maintains documents and records for five years unless other terms are agreed upon in writing.

Payment Terms

Payment Terms are Net 30 days. Prices are subject to change without notice. A standing monthly charge of 1.5% of the clients over-30-dayunpaid balance may be added to the balance after 30 days and each month thereafter (day 31, 61, 91 etc.). The laboratory accepts all major credit cards, ACH transactions, checks and cash. New clients must pay for all services rendered prior to sample collection and/or in some cases report processing. Clients must contact the MJRA accounting department to pursue a credit-based account. MJRA reserves the right to terminate the client's credit account and to refuse to perform additional services on a credit basis if any balance is outstanding for more than 60 days.

Warranty & Litigation

MJRA does not guarantee any results of its services but has agreed to use its best efforts, in accordance with the standards and practices of the industry, to cause such results to be accurate and complete. We disclaim any other warranties, expressed or implied, including a warranty of fitness for a particular purpose and warranty of merchantability. Clients agree that they shall reimburse MJRA for any and all fees, cost and litigation expenses, including reasonable attorney fees incurred by MJRA in obtaining payment for the services rendered. All costs associated with compliance with any subpoena for documents, testimony, or any other purpose relating to work performed by MJRA, for a client, shall be paid by that client. To the fullest extent permitted by law, MJRA shall only be liable for damages arising out of its gross negligence or willful misconduct. MJRA shall not be liable for damages arising from ordinary negligence. MJRA's total aggregate liability to the client for any and all claims, losses, damages, or causes of action arising out of or relating to the services performed, whether in contract, tort, or otherwise, shall be limited to the lesser of: (i) the fees paid by the client to MJRA for the specific services giving rise to the claim; or (ii) the amount paid out under MJRA's applicable professional or general liability insurance. If MJRA's insurance does not provide coverage for a claim arising from gross negligence or willful misconduct, MJRA's total aggregate liability shall not exceed an agreed maximum amount, which in no event shall exceed one hundred thousand dollars ($100,000), unless otherwise expressly agreed to in writing and approved in accordance with MJRA's internal authorization requirements. Neither MJRA nor the client shall be liable to the other for special, incidental consequential or punitive liability or damages included but not limited to those arising from delay, loss of use, loss of profits or revenues. MJRA will not be liable to the client unless the client has notified MJRA of the discovery of the alleged negligent grossly negligent act, willful misconduct, or breach within 30 days of the day of its discovery and within one year of the date of invoice.

Terms and conditions are subject to change without notice.

Reviewed and Approved by:



Christina M Kistler For Paulina Laudan Webb
Technical Director of Microbiology

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)